

**APPLICATION FOR PERMIT
TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA**

Date of filing in State Engineer's Office MAY 8 1981

Returned to applicant for correction JUL 30 1981

Corrected application filed AUG 18 1981

Map filed AUG 31 1981

The applicant Carson City

1711 N. Roop St.

Street and No. or P.O. Box No.

, of Carson City

City or Town

Nevada 89701

State and Zip Code No.

hereby make^s application for permission to appropriate the public waters of the State of Nevada, as hereinafter stated. (If applicant is a corporation, give date and place of incorporation; if a copartnership or association, give names of members.) Carson City is a Consolidated Municipality

1. The source of the proposed appropriation is underground
Name of stream, lake or other source.
2. The amount of water applied for is 6.0 second-feet
One second-foot equals 448.83 gals. per min.
(a) If stored in reservoir give number of acre-feet _____ acre-feet
3. The water to be used for Municipal purposes
Irrigation, power, mining, manufacturing, domestic, or other use. Must limit to one use.
4. If use is for:
 - (a) Irrigation (state number of acres to be irrigated) _____
 - (b) Stockwater (state number and kinds of animals to be watered) _____
 - (c) Other use (describe fully under "No. 12. Remarks") _____
 - (d) Power:
 - (1) Horsepower developed _____
 - (2) Point of return of water to stream _____
5. The water is to be diverted from its source at the following point: NW1/4 NW1/4 Section 9, T.14N., R.20E., M.D.B.&M., or at a point which bears N.30°W. a distance of
Describe as being within a 40-acre subdivision of public survey, and by course and distance to a section corner. If on unsurveyed land, 200 feet to the NW corner of said Section 9
it should be stated.
6. Place of use All of T.15N., R.20E., M.D.B.&M., E1/2 of T.15N., R.19E.,
Describe by legal subdivision, if on unsurveyed land it should be so stated.
M.D.B.&M., Sections 2,3,4,E1/2 5, and that portion of the N1/2 of the NE1/4 of Section 6 which lies within Carson City Limits, T.14N., R.20E., M.D.B.&M., Sections 31, 32, 33, 34, 35, W1/2 36 and those portions of the E1/2 of Section 36 which lie within Carson City limits T.16N., R.20E., M.D.B.&M., the S1/2 of Sections 34, 35, and 36, NE1/4 36, and those portions of the SW1/4, NW1/4 36 and the S1/2 NE1/4 35 which lie within the Carson City limits T.16N., R.19E., M.D.B.&M.
7. Use will begin about January 1 and end about December 31, of each year.
Month and Day Month and Day
8. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.) Well, pump, motor and pipeline to connect to Carson City Municipal Water System
State manner in which water is to be diverted, i.e. diversion structure, ditches and flumes, drilled well with pump and motor, etc.

9. Estimated cost of works. \$50,000
10. Estimated time required to construct works. 3 years
If well completed, describe works.
11. Estimated time required to complete the application to beneficial use. 5 years
12. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use.

This water will be used in the Carson City municipal water system.

CARSON CITY
By s/James P. Haddan

Signature, applicant or agent

Compared bl/js bp/se James P. Haddan, P.E.
1711 N. Roop St.
Carson City, NV 89701

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins, or before the Proof of Completion of Work is filed. This source is located within an area designated by the State Engineer, pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

This Permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

This permit is issued under the provisions of NRS 534.120(2) as a preferred use.

The annual duty of water under this permit is initially limited to 500 acre-feet. At least 4 ground water monitoring wells are to be located or installed within the general area of the production well under this permit at
(CONTINUED ON PAGE 2)

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed 6.0 cubic feet per second, but not to exceed 1000 acre feet annually.

Actual construction work shall begin on or before

Proof of commencement of work shall be filed before

Work must be prosecuted with reasonable diligence and be completed on or before March 29, 1992

Proof of completion of work shall be filed before April 29, 1992

Application of water to beneficial use shall be made on or before March 29, 1995

Proof of the application of water to beneficial use shall be filed on or before April 29, 1995

Map in support of proof of beneficial use shall be filed on or before N/A

Commencement of work filed IN TESTIMONY WHEREOF, I R. MICHAEL TURNIPSEED, P.E.
Completion of work filed State Engineer of Nevada, have hereunto set my hand and the seal of
Proof of beneficial use filed my office, this 29th day of March
Cultural map filed
Certificate No. Issued A.D. 19 90

Abrogated By 54865-T 1.0 cfs
218 (Rev. 9-80) Temp.
Abrogated By 54865

[Signature]
State Engineer

(PERMIT TERMS CONTINUED)

locations approved by the State Engineer. These monitoring wells must be installed prior to any diversion of ground water allowed by this permit. The monitoring wells must penetrate at least 75 feet below the existing water table. The annual duty of water allowed by this permit may be raised to a maximum of 1000 acre-feet in stages and as approved and authorized by the State Engineer only after the State Engineer has determined that the additional withdrawal will not adversely affect existing rights or the ground water resource. The permittee will maintain pumping records on the amounts of water withdrawn and submit copies of these records to the State Engineer on a monthly basis. Water level measurements will be maintained on the monitoring wells and copies of these records will be submitted to the State Engineer on a monthly basis.

